

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE		PAGE 1 OF 2 PAGES	
2. AMENDMENT/MODIFICATION NO. 0002		3. EFFECTIVE DATE 05/27/99		4. REQUISITION/PURCHASE REQ. NO. W81C8X-9098-0960		5. PROJECT NO. <i>(If applicable)</i>
6. ISSUED BY CODE		7. ADMINISTERED BY <i>(If other than Item 6)</i> CODE				
Contracting Division US ARMY ENGR DISTRICT ST. LOUIS 1222 Spruce Street, Room 4.207 St. Louis, Mo 63103 JOAN C. BRICKEY 314 331-8521						
8. NAME AND ADDRESS OF CONTRACTOR <i>(No., street, county, State and ZIP Code)</i>				(X) 9A. AMENDMENT OF SOLICITATION NO. X DACW43-99-B-0222 9B. DATED <i>(SEE ITEM 11)</i> 05/07/99		
				10A. MODIFICATION OF CONTRACT/ORDER NO.		
				10B. DATED <i>(SEE ITEM 13)</i>		
CODE		FACILITY CODE				

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended, ☒ is not extended.

Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. Accounting and Appropriation Data *(If required)*

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

(X)	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: <i>(Specify authority)</i> THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES <i>(such as changes in paying office, appropriation date, etc.)</i> . SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER <i>(Specify type of modification and authority)</i>

E. IMPORTANT: Contractor ☐ is not, ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION *(Organized by UCF section headings, including solicitation/contract subject matter where feasible.)*

AMENDMENT OF SOLICITATION

BOULDER SEWAGE TREATMENT PLANT REPLACEMENT

See page 2 for changes

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER <i>(Type or print)</i>		16A. NAME AND TITLE OF SIGNER <i>(Type or print)</i>	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____	16C. DATE SIGNED
<i>(Signature of person authorized to sign)</i>		<i>(Signature of Contracting Officer)</i>	

SF 30 CONTINUATION SHEET

SPECIFICATIONS:

SECTION 16400 - ELECTRICAL WORK AND EQUIPMENT: Page 16400-5, paragraph 2.4.1, after paragraph 2.4.1 insert new paragraph 2.4.2 as follows:

"2.4.2 Emergency Power Generator Receptacle. The Contractor shall supply receptacle and matching plug for the emergency power generator. Receptacle shall be the angle type with screw cap. Receptacle shall be waterproof construction, 200A., 600V. AC, 250V. DC, 2 pole 3 wire."

DRAWINGS:

Drawing No. K-C-5 / P-1: DEMOLITION PLAN: Delete note reading "-REMOVE TREES" at the west side of the sewage treatment plant. All trees within the construction limits will be cleared, grubbed and removed by the Government prior to the start of construction.